

Virginia City Hybrid Energy Center
Response to Data Request
Hullihen Moore, Virginia Air Pollution Control Board

Question (Page No. 1):

The average Btu content of the coal burned by all Virginia EGUs combined for the years 2005, 2006, and 2007. The average should be weighted by ton.

Response:

Weighted Average BTU Content for All Stations from 2005 – 2007 Combined.

Stations	Altavista	Bremo Bluff	Chesapeake	Chesterfield	Clover	Hopewell	Mecklenburg	Southampton	Yorktown
2005-2007 Weighted Avg	12,713	12,161	12,237	12,539	12,606	12,359	12,646	12,467	12,785

Weighted Average BTU Content for All Stations Combined From 2005 - 2007

Year	Weighted Avg Btu Content
2005	12,589
2006	12,536
2007	12,402